



# ELECTRICAL POWER DISTRIBUTION

CEC-NRCI-ELC-01-E (Created 01/20)



CERTIFICATE OF INSTALLATION		NRCI-ELC-01-E
Electrical Power Distribution		(Page 2 of 5)
Project Name:	Enforcement Agency:	Permit Number:
Project Address:	City:	Zip Code:

**A. Service Electrical Metering**

Indicate by checking one of the three boxes below if the electrical power distribution system is in compliance with Section 130.5(a).

- For newly installed electrical service in newly constructed buildings, Service Electrical Metering is required according to Section 130.5(a). *Fill out Column 1 thru 6 of table below.*
- For new or replacement electrical service equipment in existing buildings, Service Electrical Metering is required according to Section 141.0(b)2Pi. *Fill out Column 1 thru 6 of table below.*
- EXCEPTION to requirements of the Electrical Service Metering: Service or feeder for which the utility company provides a metering system that indicates instantaneous kW demand and kWh for a utility-defined period. *Fill out Column 1, 3, 6 and 7 of table below with the compliance information.*
- EXCEPTION to requirements of the Electrical Service Metering: Electrical power distribution systems subject to California Electrical Code Article 517. *Not required to fill out.*

*Fill out a separate line for each electrical service that is connected to the building. If additional table space is needed for electrical service information, submit additional page with the information.*

Electrical Service Schedule	Electrical Service Rating		Metering Capabilities (check all that are present)		Exception to 130.5(a)	
	02	03	04	05	06	07
01		Instantaneous (at the time) kW	Historical peak (kW)	Tracking kWh for a user- definable period	kWh per rate period	Utility metering system
Electrical Service Designation/Location/Description	kVA					
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
		<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

# ELECTRICAL POWER DISTRIBUTION

CEC-NRCI-ELC-01-E (Created 01/20)



CERTIFICATE OF INSTALLATION		NRCI-ELC-01-E
Electrical Power Distribution		(Page 3 of 5)
Project Name:	Enforcement Agency:	Permit Number:
Project Address:	City:	Zip Code:

**B. Separation of Electrical Circuits for Electrical Energy Monitoring**

Check all boxes below if the electrical power distribution system is in compliance with Section 130.5(b).

- The electrical power distribution system meets the separation of electrical circuits for electrical energy monitoring requirement of Section 130.5(b). The electrical power distribution systems is designed so that measurement devices can monitor the electrical energy usage of load types according to TABLE 130.5-B.
- Describe the electrical power distribution system installed and the compliance method chosen in meeting the requirement of Section 130.5(b). Use the space below to include the information. Examples of compliance methods are detailed in Nonresidential Compliance Manual Chapter 8.
- EXCEPTION to requirements of the Separation of Electrical Circuits for Electrical Energy Monitoring: Electrical power distribution systems subject to California Electrical Code Article 517. *Not required to fill out.*

Fill out Column 1 thru 3 with the compliance information.

General Information	Electrical Power Distribution System Information and Method of Compliance	Electrical Service Rating
01	02	03
Electrical Service Designation/Location/Description	Describe the electrical power distribution system installed and the compliance method used.	kVA

Field Inspector Notes:




CERTIFICATE OF INSTALLATION		NRCI-ELC-01-E
Electrical Power Distribution		(Page 4 of 5)
Project Name:	Enforcement Agency:	Permit Number:
Project Address:	City:	Zip Code:

**C. Voltage Drop**

Check all boxes below if the electrical power distribution system is in compliance with Section 130.5(c).

- The electrical power distribution system meets the voltage drop requirement of Section 130.5(c). The maximum combined voltage drop on feeder conductors and branch circuit conductors to the farthest connected load or outlet does not exceed 5%.
- Voltage drop calculation documents showing compliance to Section 130.5(c) are submitted as part of the compliance document submittal.

**D. Circuit Controls for 120-Volt Receptacles and Controlled Receptacles**

Check one or more boxes below for applicable requirements of Section 130.5(d) for the electrical power distribution system.

- The control is capable of automatically shutting OFF the controlled receptacles when the space is typically unoccupied, either at the receptacle or circuit level. For the automatic time switch control, it incorporates an override control that allows the controlled receptacle to remain ON for no more than 2 hours when an override is initiated and an automatic holiday "shut-OFF" feature that turns OFF all loads for at least 24 hours and then resumes the normally scheduled operation. Countdown timer switches are not to be used to comply with the automatic time switch control requirements. The controls meet the requirement of Section 130.5(d)1.
- There is at least one controlled receptacle within 6 feet from each uncontrolled receptacle. Where receptacles are installed in modular furniture in open office area, at least one controlled receptacle is installed at each workstation. The receptacles meet the requirement of Section 130.5(d)2.
- There are installed split wired receptacles with at least one controlled and one uncontrolled receptacle. Where receptacles are installed in modular furniture in open office area, at least one controlled receptacle is installed at each workstation. The receptacles meet the requirement of Section 130.5(d)2.
- Permanent and durable marking for controlled receptacles or circuits to differentiate them from uncontrolled receptacles or circuits is provided. The markings meet the requirement of Section 130.5(d)3.
- For hotel and motel guest rooms, there are controlled receptacles for at least one-half of the 120-volt receptacle in each guest room. Electric circuits serving controlled receptacles in guestrooms are installed to have captive key controls, occupancy sensing controls, or automatic controls so the power is switched off no longer than 30 minutes after the guest room has been vacated. The receptacles meet the requirement of Section 130.5(d)4.
- Receptacles that are only for the following purposes are excepted from Section 130.5(d):
  - Receptacles specifically for refrigerators and water dispensers in kitchen areas.
  - Receptacles located a minimum of six feet above the floor that are specifically for clocks.
  - Receptacles for network copiers, fax machines, A/V and data equipment other than personal computers in copy rooms.
  - Receptacles on circuits rated more than 20 amperes.
  - Receptacles connected to an uninterruptible power supply (UPS) that are intended to be in continuous use, 24 hours per day/365 days per year, and are marked to differentiate them from other uncontrolled receptacles or circuits.

**ELECTRICAL POWER DISTRIBUTION**

CEC-NRCI-ELC-01-E (Created 01/20)

CALIFORNIA ENERGY COMMISSION



CERTIFICATE OF INSTALLATION		NRCI-ELC-01-E
Electrical Power Distribution		(Page 5 of 5)
Project Name:	Enforcement Agency:	Permit Number:
Project Address:	City:	Zip Code:

**DOCUMENTATION AUTHOR'S DECLARATION STATEMENT**

1. I certify that this Certificate of Installation documentation is accurate and complete.

Documentation Author Name:	Documentation Author Signature:
Documentation Author Company Name:	Date Signed:
Address:	CEA/HERS Certification Identification (If applicable):
City/State/Zip:	Phone:

**RESPONSIBLE PERSON'S DECLARATION STATEMENT**

I certify the following under penalty of perjury, under the laws of the State of California:

- The information provided on this Certificate of Installation is true and correct.
- I am eligible under Division 3 of the Business and Professions Code in the applicable classification to accept responsibility for the system design, construction, or installation of features, materials, components, or manufactured devices for the scope of work identified on this Certificate of Installation and attest to the declarations in this statement (responsible builder/installer), otherwise I am an authorized representative of the responsible builder/installer.
- The constructed or installed features, materials, components or manufactured devices (the installation) identified on this Certificate of Installation conforms to all applicable codes and regulations, and the installation conforms to the requirements given on the plans and specifications approved by the enforcement agency.
- I reviewed a copy of the Certificate of Compliance approved by the enforcement agency that identifies the specific requirements for the scope of construction or installation identified on this Certificate of Installation, and I have ensured that the requirements that apply to the construction or installation have been met.
- I will ensure that a completed signed copy of this Certificate of Installation shall be posted, or made available with the building permit(s) issued for the building, and made available to the enforcement agency for all applicable inspections. I understand that a completed signed copy of this Certificate of Installation is required to be included with the documentation the builder provides to the building owner at occupancy.

Responsible Builder/Installer Name:	Responsible Builder/Installer Signature:	
Company Name: (Installing Subcontractor or General Contractor or Builder/Owner)	Position With Company (Title):	
Address:	CSLB License:	
City/State/Zip:	Phone:	Date Signed: